

**Analytical Results**

**TASK NO: 110222025**

**Report To:** Ken Gee  
**Company:** Todd Creek Village Metro District  
P.O. Box 490  
Brighton CO 80601

**Bill To:** Ken Gee  
**Company:** Todd Creek Village Metro District  
P.O. Box 490  
Brighton CO 80601

<b>Task No.:</b> 110222025	<b>Date Received:</b> 2/22/11
<b>Client PO:</b>	<b>Date Reported:</b> 3/2/11
<b>Client Project:</b> Todd Creek Village Metro District CO 0101157	<b>Matrix:</b> Water - Drinking

**Customer Sample ID** Todd Creek R.O. Plant  
**Sample Date/Time:** 2/22/11 12:50 PM  
**Lab Number:** 110222025-01

Test	Result	Method	LQL	Date Analyzed	Analyzed By
<i>Total</i>					
Antimony	< 0.001 mg/L	EPA 200.8	0.001	2/28/11	JDC
Arsenic	0.002 mg/L	EPA 200.8	0.001	2/28/11	JDC
Barium	0.009 mg/L	EPA 200.8	0.001	2/28/11	JDC
Beryllium	< 0.001 mg/L	EPA 200.8	0.001	2/28/11	JDC
Cadmium	< 0.001 mg/L	EPA 200.8	0.001	2/28/11	JDC
Chromium	0.002 mg/L	EPA 200.8	0.001	2/28/11	JDC
Mercury	< 0.0001 mg/L	EPA 200.8	0.0001	2/28/11	JDC
Nickel	< 0.001 mg/L	EPA 200.8	0.001	2/28/11	JDC
Selenium	< 0.001 mg/L	EPA 200.8	0.001	2/28/11	JDC
Sodium	78.2 mg/L	SM 3111-B	0.1	2/28/11	JDC
Thallium	< 0.001 mg/L	EPA 200.8	0.001	2/28/11	JDC

**Abbreviations/ References:**

LQL = Lower Quantification Limit  
mg/L = Milligrams Per Liter or PPM  
ug/L = Micrograms Per Liter or PPB  
mpn/100 mls = Most Probable Number Index/ 100 mls  
Date Analyzed = Date Test Completed  
SM = "Standard Methods for the Examination of Water and Wastewater"; APHA; 19th Edition; 1995  
EPA = "Methods of Chemical Analysis of Water and Wastes"; USEPA; EPA-600/4-79-020 Rev 3/83



DATA APPROVED FOR RELEASE BY