



**Colorado Department of Public Health and Environment
Compliance Assurance and Data Management Unit
REPORTING FORM FOR ORGANIC CONTAMINANTS ANALYSES**

SAMPLER: PLEASE FILL OUT ONE FORM FOR EACH SAMPLE

Are these results to be used to fulfill compliance monitoring requirements? Yes or No

Is this a check or confirmation sample? Yes No

PWSID: CO 0101157 COUNTY: Adams DATE COLLECTED: 2/22/11

SYSTEM/ESTABLISHMENT NAME: Todd Creek Village Metro District

SYSTEM ADDRESS: P.O. Box 490 Brighton CO 80601
Street address/ PO Box CITY STATE ZIP

CONTACT PERSON: Ken Gee PHONE: 303-637-0344

SAMPLE COLLECTED BY: Ken Gee TIME COLLECTED: _____

ENTRY POINT (Finished Water) SAMPLE SOURCE WATER SAMPLE
FOR ENTRY POINT SAMPLES PLEASE INDICATE: Chlorinated OTHER TREATMENT
Finished - Not Treated (No Chlorine or other treatment)

STATE ENTRY POINT CODE: EP 016 SOURCE(S) REPRESENTED: Laramie Fox Hills Wells 3&7 Plte

DO SAMPLES NEED TO BE COMPOSITED BY THE LABORATORY? Yes No

NOTE: CHECK OR CONFIRMATION SAMPLES CANNOT BE COMPOSITED

For Laboratory Use Only Below This Line

LABORATORY SAMPLE # 110222028-01 CLIENT NAME or ID# TODDCREEK

LABORATORY NAME Colorado Analytical Laboratory

LAB PHONE #: (303) 659-2313 DATE RECEIVED IN LABORATORY: 2/22/11

COMMENTS: _____

EPA 531.1 - Subcontracted to outside laboratory

EPA 549.2 - Subcontracted to outside laboratory

REGULATED PHASE I, II, V ORGANIC CHEMICALS - SOC's
UNITS MUST BE REPORTED IN ug/L

CONTAMINANT	CAS#	RESULT ug/L	MCL in ug/L	STANDARD METHOD	Lab Report Limit ug/L	Lab MDL ug/L	BLANK RESULT
2,4,-D	94-75-7	BDL	70	EPA 515.4	0.1	0.1	< 0.1
2,4,5-TP	93-72-1	BDL	50	EPA 515.4	0.2	0.2	< 0.2
Alachlor	15972-60-8	BDL	2	EPA 525.2	0.2	0.2	< 0.2
Atrazine	1912-24-9	BDL	3	EPA 525.2	0.1	0.1	< 0.1
Benzo(a)pyrene	50-32-8	BDL	0.2	EPA 525.2	0.02	0.02	< 0.02
Carbofuran	1563-66-2	BDL	40	EPA 531.1	0.9	0.43	< 0.9
Chlordane	57-74-9	BDL	2	EPA 505	0.2	0.2	< 0.2
Dalapon	75-99-0	BDL	200	EPA 515.4	1	1	< 1
Dibromochloropropane	96-12-8	BDL	0.2	EPA 504.1	0.01	0.01	< 0.01
Dinoseb	85-85-7	BDL	7	EPA 515.4	0.2	0.2	< 0.2
Diquat	85-00-7	BDL	20	EPA 549.2	0.4	0.23	< 0.4
Di(2-ethylhexyl)adipate	103-23-1	BDL	400	EPA 525.2	0.6	0.6	< 0.6
Di(2-ethylhexyl)phthalate	117-81-7	BDL	6	EPA 525.2	0.6	0.6	< 0.6
Endothall	145-73-3	BDL	100	EPA 548.1	9	9	< 9
Endrin	72-20-8	BDL	2	EPA 505	0.01	0.01	< 0.01
Ethylene dibromide	106-93-4	BDL	0.05	EPA 504.1	0.02	0.02	< 0.02
Heptachlor	76-44-8	BDL	0.4	EPA 505	0.04	0.04	< 0.04
Heptachlor epoxide	1024-57-3	BDL	0.2	EPA 505	0.02	0.02	< 0.02
Hexachlorobenzene	118-74-1	BDL	1	EPA 505	0.1	0.1	< 0.1
Hexachlorocyclopentadiene	77-47-4	BDL	50	EPA 505	0.1	0.1	< 0.1
Lindane	58-89-9	BDL	0.2	EPA 505	0.02	0.02	< 0.02
Methoxychlor	72-43-5	BDL	40	EPA 505	0.1	0.1	< 0.1
Oxamyl	23135-22-0	BDL	200	EPA 531.1	1	0.48	< 1
Pentachlorophenol	87-86-5	BDL	1	EPA 515.4	0.04	0.04	< 0.04
Picloram	1918-02-1	BDL	500	EPA 515.4	0.1	0.1	0.289
Polychlorinated biphenyl's	1336-36-3	BDL	0.5	EPA 505	0.2	0.2	< 0.2
Simazine	122-34-9	BDL	4	EPA 525.2	0.07	0.07	< 0.07
Toxaphene	8001-35-2	BDL	3	EPA 505	1	1	< 1

UNREGULATED ORGANIC CHEMICALS - SOC's
UNITS MUST BE REPORTED IN ug/L

CONTAMINANT	CAS#	RESULT ug/L	MCL in ug/L	STANDARD METHOD	Lab Report Limit ug/L	Lab MDL ug/L	BLANK RESULT
3-Hydroxycarbofuran	(Unk)	BDL		EPA 531.1	0.5	0.42	< 0.5
Aldicarb	116-06-3	BDL		EPA 531.1	0.5	0.44	< 0.5
Aldicarb sulfone	1646-88-4	BDL		EPA 531.1	0.7	0.49	< 0.7
Aldicarb sulfoxide	1646-87-3	BDL		EPA 531.1	0.5	0.46	< 0.5
Aldrin	309-00-2	BDL		EPA 505	0.05	0.05	< 0.05
Butachlor	23184-66-9	BDL		EPA 525.2	0.25	0.25	< 0.25
Carbaryl	63-25-2	BDL		EPA 531.1	0.5	0.45	< 0.5
Dicamba	1918-00-9	BDL		EPA 515.4	0.5	0.5	< 0.5
Dieldrin	60-57-1	BDL		EPA 505	0.01	0.01	< 0.01
Methomyl	16752-77-5	BDL		EPA 531.1	0.5	0.49	< 0.5
Metolachlor	51218-45-2	BDL		EPA 525.2	0.25	0.25	< 0.25
Metribuzin	21087-64-9	BDL		EPA 525.2	0.25	0.25	< 0.25
Propachlor	1918-16-7	BDL		EPA 525.2	0.25	0.25	< 0.25

Codes used:

NT = Not tested for Compound

Lab MDL = Laboratory Method Detection Level

ug/L = Micrograms per liter

MCL = Maximum Contaminant Level

BDL = Indicates that the compound was analyzed for, but was below the Lab MDL.

Lab Report Limit = Level of Quantitation (LOQ).



Laboratory Manager

3/10/11

Laboratory Results Reviewed and Approved by

TITLE

DATE

Colorado Department of Public Health and Environment
WQCD-CADM
4300 Cherry Creek Drive South
Denver, CO 80246-1530