

**Colorado Department of Public Health and Environment- Water Quality Control Division  
 Drinking Water Program - Compliance Assurance and Data Management Unit  
 4300 Cherry Creek Drive South, Denver, CO 80246-1530**

DBP Form 1 - Total Trihalomethane Analysis Laboratory Report Form										
Section I (to be completed by the Public Water Systems only)					Section II (to be completed by Laboratories only)					
Public Water System Information					Laboratory Information					
PWSID#: CO 0101157										
System Name: Todd Creek Village Metro District					Laboratory Name: Colorado Analytical Laboratory					
Address: P.O. Box 490, Brighton, CO 80601					Contact Person: Customer Service			Phone: 303-659-2313		
Contact Person: Ken Gee					Comments:					
					<i>Steve Nichols</i>			Laboratory Manager		3/4/11
System Authorized Signature			Title		Laboratory Authorized Signature			Title		Date
PWS to complete first 3 columns			Laboratories to complete columns 4-6 and 8-11							
Sample Date	Collector	Sample Location Designation#	Date Lab Received	Date Lab Analyzed	Laboratory Sample ID #	Analyte	Analytical Method	ug/L Blank Result	ug/L Lab MDL	ug/L Result
2/23/11	Ken Gee	5061 E. 160th Ave. Max Res	2/23/11	2/25/11	110223020-01A	Chloroform	EPA 524.2	BDL	0.5	0.6
2/23/11	Ken Gee	5061 E. 160th Ave. Max Res	2/23/11	2/25/11	110223020-01A	Bromodichloromethane	EPA 524.2	BDL	0.5	2.0
2/23/11	Ken Gee	5061 E. 160th Ave. Max Res	2/23/11	2/25/11	110223020-01A	Dibromochloromethane	EPA 524.2	BDL	0.5	4.7
2/23/11	Ken Gee	5061 E. 160th Ave. Max Res	2/23/11	2/25/11	110223020-01A	Bromoform	EPA 524.2	BDL	0.5	4.7
2/23/11	Ken Gee	5061 E. 160th Ave. Max Res	2/23/11	2/25/11	110223020-01A	Total Trihalomethanes	EPA 524.2	BDL		11.9