



**GENERAL NOTES:**

1. WATER METER FURNISHED AND INSTALLED BY TODD CREEK VILLAGE METROPOLITAN DISTRICT.
2. ONLY THE METER IS THE PROPERTY OF THE DISTRICT.
3. ALL METER PITS SHALL BE STAKED FOR FINISHED GRADE IF INSTALLATION PRECEEDS CONSTRUCTION.
4. WATER DISTRICT PERSONNEL SHALL INSPECT THE SERVICE LINE FROM THE CURB STOP TO THE HOUSE (24 HOUR NOTICE REQUIRED FOR INSPECTION).
5. SERVICES BELOW ELEVATION 5090 MUST USE TANDEM COPPER SETTER WITH PRV.

**RG AND ASSOCIATES, LLC**  
 4885 Ward Road, Suite 100 • Wheat Ridge, CO • 80083  
 303-293-8107 • 303-293-8106 (fax) • www.rgengineers.com

<b>TODD CREEK VILLAGE METROPOLITAN DISTRICT</b>	
<b>OUTSIDE SETTING FOR 3/4" (POTABLE)</b>	
Scale: <i>NONE</i>	Date: <i>FEB 2010</i>
Approved:	Rev. <i>12/07/17</i>

GENERAL METER NOTES

1. METER LOCATION SHALL BE APPROVED BY TODD CREEK METROPOLITAN DISTRICT. METER SETTINGS LARGER THAN ONE INCH SHALL BE APPROVED IN THE FIELD BY THE WATER DEPARTMENT PRIOR TO INSTALLATION OF ANY SERVICE PIPE OR TAP. CALL TO MAKE APPOINTMENT FOR ON-SITE APPROVAL MEETING.
2. METERS WILL NOT BE SET/APPROVED UNLESS METER SETTING AND SERVICE LINE ARE IN FULL COMPLIANCE WITH THE ENGINEERING STANDARDS, STANDARD DRAWINGS, AND APPROVED PROJECT DRAWINGS AS APPLICABLE.
3. DOMESTIC WATER SERVICES SHALL RUN AT A NINETY DEGREE ANGLE FROM WATER MAIN WITH NO BENDS, NO CHANGES IN PIPE SIZE OR PIPE MATERIAL, FOR INDOOR METERS, UNTIL FIVE FEET PAST THE CURB STOP.
4. BYPASS IS REQUIRED ON ALL METERS ONE AND ONE HALF INCH AND LARGER, EXCEPT FOR IRRIGATION SERVICES. BYPASSES ARE NOT PERMITTED ON IRRIGATION SERVICES.
5. ALL MATERIALS USED FOR SERVICE PIPES, VALVES, METER SETTINGS AND METERS SHALL CONFORM TO APPLICABLE SECTIONS OF THE ENGINEERING STANDARDS, LATEST EDITION. ALL VARIANCES AND DEVIATIONS MUST BE APPROVED BY CUSTOMER SERVICE FIELD SECTION PRIOR TO INSTALLATION.
6. ANY METER SETTING OTHER THAN THOSE SPECIFICALLY SHOWN AND DETAILED HEREIN SHALL BE CONSIDERED NON-STANDARD AND SHALL REQUIRE PRIOR APPROVAL BY TODD CREEK METROPOLITAN DISTRICT, BASED ON DRAWINGS SHOWING ENTIRE SERVICE LINE, FITTINGS, METER SETTING, LOCATION OF NEAREST PUBLIC STREET, AND STRUCTURAL DESIGN OF VAULT. CURB STOPS/VALVES MAY NOT BE PLACED IN AREAS WHERE VEHICLES MAY PARK OVER THEM.
7. BACKFLOW PREVENTION DEVICES ARE REQUIRED.
8. ALL METERS TO BE SET BY THE DISTRICT.



**TODD CREEK VILLAGE  
METROPOLITAN DISTRICT**

**GENERAL METER NOTES**

Scale: <i>NONE</i>	Date: <i>FEB 2010</i>
Approved:	<i>Rev.12/07/2017</i>

SHEET 40A